



Federal Express 8047 4954 2291

December 4, 2014

Ms. Ingrid H. Hopkins
Water Protection Division (3WP42)
US EPA – Region III
1650 Arch Street
Philadelphia, PA 19103-3029
(215) 814-5437
hopkins.ingrid@epa.gov

**RE: Benning Road Generating Station – NPDES Permit No. DC 0000094
Re-sample for pH at Outfall 101**

Dear Ms. Hopkins,

Oct 23, 2014 letter
Oct 21, 2014 call from H. Burkhardt
This letter is a follow-up to our October 21, 2014 letter, in which it was indicated that we will re-test Outfall 101 during the next qualifying storm event to assess whether elevated pH conditions are persisting.

On December 1, 2014 at approximately 6:45 pm, a composite pH sample was taken from Outfall 101 during a qualifying storm event. The reading indicated a pH value of 8.36, which is in compliance with the permit limit of 6 – 8.5.

Please contact me at (703) 253-1787 or by electronic mail at mwilliams@pepcoenergy.com if you need additional information.

Respectfully yours,

Michael V. Williams

**Michael V. Williams
Power Plant Asset Manager
Pepco Energy Services, Inc.**

Cc: File